

CMI Architectural Products, Inc.  
608 Fourth Street SE  
DeSmet, SD 57231  
Toll Free: (800) 324-2070  
Phone: (605) 854-3326  
Fax: (605) 854-3620  
Web Site: www.cmiarch.com

## Product Guide Specification

*Specifier Notes:* This product guide specification is written according to the Construction Specifications Institute (CSI) Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, contained in the *CSI Manual of Practice*.

The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the drawings.

Delete all "*Specifier Notes*" when editing this section.

### SECTION 08120

#### ALUMINUM FLUSH DOORS

*Specifier Notes:* This section covers CMI Architectural Products, Inc. aluminum flush doors with aluminum frames. Consult CMI for assistance in editing this section for the specific application.

#### PART 1 GENERAL

##### 1.1 SECTION INCLUDES

- A. Aluminum flush doors with aluminum frames.

##### 1.2 RELATED SECTIONS

*Specifier Notes:* Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

- A. Section 08100 - Metal Doors and Frames.
- B. Section 08300 - Specialty Doors.
- C. Section 08400 - Entrances and Storefronts.
- D. Section 08710 - Door Hardware.

### 1.3 REFERENCES

*Specifier Notes:* List standards referenced in this section, complete with designations and titles. This article does not require compliance with standards, but is merely a listing of those used.

- A. AAMA 1503.1 - Thermal Transmittance and Condensation Resistance of Windows, Doors and Glazed Wall Sections
- B. ASTM B 209 - Aluminum and Aluminum-Alloy Sheet and Plate.
- C. ASTM B 221 - Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tube

### 1.4 PERFORMANCE REQUIREMENTS

- A. General: Provide door assemblies that have been designed and fabricated to comply with specified performance requirements, as demonstrated by testing manufacturer's corresponding standard systems.

### 1.5 SUBMITTALS

- A. Comply with Section 01330 - Submittal Procedures.
- B. Product Data: Submit manufacturer's product data, including description of materials, components, fabrication, finishes, and installation.
- C. Shop Drawings: Submit manufacturer's shop drawings, including elevations, sections, and details, indicating dimensions, tolerances, materials, fabrication, doors, panels, framing, hardware schedule, finish, options, and accessories.
- D. Samples:
  - 1. Door: Submit manufacturer's sample of door showing face sheets, core, framing, finish, and accessories.
  - 2. Color: Submit manufacturer's samples of standard colors of doors and frames.
- E. Test Reports: Submit certified test reports from qualified independent testing agency indicating doors comply with specified performance requirements.
- F. Manufacturer's Project References: Submit list of successfully completed projects including project name and location, name of architect, and type and quantity of doors manufactured.
- G. Maintenance Manual: Submit manufacturer's maintenance and cleaning instructions for doors, including maintenance and operating instructions for hardware.
- H. Warranty: Submit manufacturer's standard warranty.

### 1.6 QUALITY ASSURANCE

- A. Manufacturer's Qualifications: Continuously engaged in manufacturing of commercial aluminum entry doors, with a minimum of 10 years successful experience.

## 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying opening door mark and manufacturer.
- B. Storage: Store materials in clean, dry area indoors in accordance with manufacturer's instructions.
- C. Handling: Protect materials and finish from damage during handling and installation.

## 1.8 WARRANTY

*Specifier Notes: Consult CMI for additional warranty information.*

- A. Warrant doors, frames, and factory hardware against failure in materials and workmanship, including excessive deflection, faulty operation, defects in hardware installation, and deterioration of finish or construction in excess of normal weathering.
- B. Warranty Period: One year (or as specified) starting from the date of substantial completion.

## PART 2 PRODUCTS

### 2.1 MANUFACTURER

- A. CMI Architectural Products, Inc. DeSmet, SD

### 2.2 ALUMINUM FLUSH DOORS

- A. Model: 9000 Flush Doors with aluminum face sheets.

*Specifier Notes: Specify the door opening size of the 9000 flush doors.*

- B. Door Opening Size: As indicated on the drawings.
- C. Construction:
  - 1. Door Thickness: 1-3/4 inches.
  - 2. Stiles and Rails: Aluminum Alloy 6063-T5, minimum of 4-inch depth.
  - 3. Corners: Mitered.
  - 4. Provide joinery of 3/8-inch diameter full-width tie rods through extruded splines top and bottom as standard tubular shaped stiles and rails reinforced to accept hardware as specified.
  - 5. Securing Internal Door Extrusions: 3/16-inch angle blocks and hex-type nuts for joinery. Welds, glue, or other methods are not acceptable.
  - 6. Furnish extruded stiles and rails with integral reglets to accept fully framed face sheet and lock it into place.
  - 7. Rail caps or other face sheet capture methods are not acceptable.
  - 9. Meeting Stiles: Wool pile weatherstripping. Extrude meeting stile to include integral pocket to accept wool pile weathering.
- D. Face Sheet:
  - 1. Material: 0.120 inch thick aluminum

2. Texture: [Smooth] [Vertical Rib Pattern 10] [Custom – architect to specify]

**Specifier Notes: Delete rigid backing if not required**

3. Rigid Backing: not required

**E. Core:**

**POLYSTYRENE BOARD CORE - STANDARD:**

1. Material: Expanded polystyrene bead board OR Extruded polystyrene board insulation.
2. Density: **Select** [STANDARD 2] **or** [OPTIONAL] 3 pounds per cubic foot.
3. R-value: Minimum 3.0 per inch.

**POLYISOCYANURATE BOARD CORE OPTION**

1. Material: Polyisocyanurate urethane board insulation.
2. Density: **Select** [2] **OR** [3] **OR** [4] **OR** [5] **OR** [6] pounds per cubic foot.
3. R-value: Minimum 5.0 per inch.

**F. Cutouts:**

1. Manufacture doors with cutouts for required vision lites, louvers, and panels.
2. Factory install vision lites, louvers, and panels.

**G. Hardware:**

1. Premachine doors in accordance with templates from specified hardware manufacturers and hardware schedule.
2. Factory install hardware.

## **2.3 MATERIALS**

**A. Aluminum Members:**

1. Extrusions: ASTM B 221.
2. Sheet and Plate: ASTM B 209.
3. Alloy and Temper: As required by manufacturer for strength, corrosion resistance, application of required finish, and control of color.

**B. Components: Door and frame components from same manufacturer.**

**C. Fasteners:**

1. Material: Aluminum, 18-8 stainless steel, or other non-corrosive metal.
2. Compatibility: Compatible with items to be fastened.
3. Exposed Fasteners: Screws with finish matching items to be fastened.

## **2.4 FABRICATION**

**A. Sizes and Profiles: Required sizes for door and frame units, and profile requirements shall be as indicated on the drawings.**

**B. Coordination of Fabrication: Field measure before fabrication and show recorded measurements on shop drawings.**

- C. Assembly:
  - 1. Complete cutting, fitting, forming, drilling, and grinding of metal before assembly.
  - 2. Remove burrs from cut edges.
- D. Welding: Welding of doors or frames is not acceptable.
- E. Fit:
  - 1. Maintain continuity of line and accurate relation of planes and angles.
  - 2. Secure attachments and support at mechanical joints with hairline fit at contacting members.

*Specifier Notes: Delete the following article if architectural panels are not required.*

## 2.5 ARCHITECTURAL PANELS

- A. Model: 9000 Aluminum Architectural Panels.

*Specifier Notes: Specify the size and thickness of the aluminum architectural panels.*

- 1. Size: As indicated on the drawings.
- 2. Thickness: 1 inch.

*Specifier Notes: Specify finish and texture.*

- 3. Finish: Anodized or painted.
- 4. Texture: **Select** Smooth OR Patterned

*Specifier Notes: Specify insulated panels or 1/4-inch panels.*

- 5. Insulated Panels:
  - a. Core: **Select** Rigid polystyrene OR Polyisocyanurate
  - b. Face Sheets: .120-inch thick aluminum.
  - c. Rigid Backing: non-required

## 2.6 ALUMINUM DOOR FRAMING SYSTEMS

- A. Tubular Framing:
  - 1. Size and Type: As indicated on the drawings.
  - 2. Materials: Aluminum Alloy 6063-T5, 1/8-inch minimum wall thickness.
  - 3. Removable Door Stops: 3/4 inch high with wool pile weatherstripping.
  - 4. Frame Members: Closed back, solid tube framing.
  - 5. Caulking: Caulk joints before assembling frame members.
  - 6. Joints:
    - a. Secure joints with fasteners.
    - b. Provide hairline butt joint appearance.
  - 7. Field Fabrication: Field fabrication of framing using stick material is not acceptable.
  - 8. Glazing Pockets: Integral with door framing. Applied sash is allowed only at transom jambs or where tube framing is specified.
  - 9. Hardware:
    - a. Premachine and reinforce frame members for hardware in accordance with manufacturer's standards and hardware schedule.

- b. Factory install hardware.
- 10. Anchors:
  - a. Anchors appropriate for wall conditions to anchor framing to wall materials.
  - b. Secure head and sill members of transom, side lites, and similar conditions.

## 2.6 HARDWARE

*Specifier Notes: CMI offers a wide range of hardware products and services, including furnishing and factory installing hardware. Hardware may be supplied by either CMI or the Contractor.*

- A. Premachine doors in accordance with templates from specified hardware manufacturers and hardware schedule.
- B. Factory install hardware to the greatest extent possible.

*Specifier Notes: Delete the following article if vision lites are not required.*

## 2.8 VISION LITES

*Specifier Notes: Specify 1/4-inch glass or 1-inch glass insulating units.*

- A. Factory Glazing: 1/4 inch glass or 1 inch glass insulating units (as indicated on the drawings).
- B. Lites in Exterior Doors: Allow for thermal expansion.

*Specifier Notes: Specify rectangular or curved, standard or custom lites. Specify size of lites. Consult CMI for custom lite requirements.*

- C. Rectangular Lites:
  - 1. Size: As indicated on the drawings.
  - 2. Factory glazed with interior screw-applied aluminum stops anodized to match perimeter door rails.

*Specifier Notes: Delete the following article if louvers are not required.*

## 2.9 LOUVERS

- A. Type: Aluminum, inverted Y-type, fixed blade, 12 inches minimum from bottom of door.

*Specifier Notes: Specify the size of the louvers.*

- B. Size: As indicated on the drawings.
- C. Installation: Factory installed into standard vision lite kit. Exterior side of louver to be free of fasteners.

*Specifier Notes: Delete the optional insect screen if not required.*

- D. Insect screen.

## **2.10 ALUMINUM FINISHES**

- A. Anodized finishes shall be Class I finish, 0.7 mils thick.
- B. Anodized:

*Specifier Notes: Specify one of the following standard anodized finishes. Consult CMI for availability of custom anodized finishes.*

1. #20 Clear 204-R1, AA-M21C22A31, Class II, 0.4 mils thick.
2. #21 Clear 215 R1, AA-M21C22A41, Class I, 0.7 mils thick.
3. #30 Champagne, AA-M12C22A44, Class I, 0.7 mils thick.
4. #31 Light Bronze, AA-M12C22A44, Class I, 0.7 mils thick.
5. #32 Medium Bronze, AA-M12C22A44, Class I, 0.7 mils thick.
6. #33 Dark Bronze, AA-M12C22A44, Class I, 0.7 mils thick.
7. #35 Black, AA-M12C22A44, Class I, 0.7 mils thick.

*Specifier Notes: Consult CMI for painted finishes for aluminum.*

- C. Painted: High performance fluoro carbon coating in accordance with AAMA 2605. Color as selected by architect.

## **PART 3 EXECUTION**

### **3.1 EXAMINATION**

- A. Examine areas to receive doors. Notify Architect of conditions that would adversely affect installation or subsequent utilization of doors. Do not proceed with installation until unsatisfactory conditions are corrected.

### **3.2 PREPARATION**

- A. Ensure openings to receive frames are plumb, level, square, and in tolerance.

### **3.3 INSTALLATION**

- A. Install doors in accordance with manufacturer's shop drawings and/or installation instructions.
- B. Install doors plumb, level, square, true to line, and without warp or rack.
- C. Anchor frames securely in place.
- D. Separate aluminum from other metal surfaces with bituminous coatings or other means approved by Architect.
- E. Set thresholds in bed of mastic and backseal.

- F. Install exterior doors to be weather tight in closed position.
- G. Repair minor damages to finish in accordance with manufacturer's instructions and as approved by Architect.
- H. Remove and replace damaged components that cannot be successfully repaired as determined by the Architect.

*Specifier Notes:* Delete the following article if manufacturer's field services are not required for the specific application.

### **3.4 FIELD QUALITY CONTROL**

- A. Manufacturer's Field Services: Manufacturer's representative shall provide technical assistance and guidance for installation of doors.

### **3.5 ADJUSTING**

- A. Adjust doors, hinges, and locksets for smooth operation without binding.

### **3.6 CLEANING**

- A. Clean doors promptly after installation in accordance with manufacturer's instructions.
- B. Do not use harsh cleaning materials or methods that would damage finish.

### **3.7 PROTECTION**

- A. Protect installed doors to ensure that, except for normal weathering, doors will be without damage or deterioration at time of substantial completion.

**END OF SECTION**